



## SECTION 08360 (08 36 00)

### OVERHEAD DOORS

Display hidden notes to specifier. (Don't know how? [Click Here](#))

*Copyright 2006 – 2025 ARCAT, Inc. - All rights reserved*

**\*\* NOTE TO SPECIFIER \*\*** C.H.I. Overhead Doors; Overhead Doors.

This section is based on the products of C.H.I. Overhead Doors, which is located at:  
1485 Sunrise Drive.

Arthur, IL 61911.

Tel: (800) 677-2650.

Fax: (800) 738-5006.

E-mail: [aia@chiohd.com](mailto:aia@chiohd.com)

Web: [www.chiohd.com](http://www.chiohd.com).

[\[Click Here\]](#) for more information

C.H.I. Overhead Doors, a NUCOR (NYSE: NUE) company, has been manufacturing overhead doors for over 40 years. Through our authorized dealer network across North America, you can access our entire product line including commercial and residential sectional doors, rolling service and fire doors or shutters, grilles, and high-performance doors. C.H.I. integrates premium-quality materials with superior designs, workmanship, and a strong focus on end user satisfaction. Dedicated to continuing the best customer service and dealer support in the industry, it is apparent why C.H.I. is referred to as "The Door to Quality". C.H.I. is headquartered in Arthur, IL with additional manufacturing in Terre Haute, IN. For more information visit [chiohd.com](http://chiohd.com).

### PART 1 GENERAL

#### 1.1 SECTION INCLUDES

- A. Commercial insulated steel sandwich doors.

#### 1.2 RELATED SECTIONS

**\*\* NOTE TO SPECIFIER \*\*** Delete any sections below not relevant to this project; add others as required.

- A. Section 05 10 00 - Structural Metal Framing.
- B. Section 06 10 00 - Rough Carpentry.
- C. Section 09 90 00 - Painting and Coating.
- D. Section 26 05 00 - Common Work Results for Electrical.

#### 1.3 REFERENCES

**\*\* NOTE TO SPECIFIER \*\*** Delete references from the list below that are not required by the text of the edited section.

- A. America National Standards Institute (ANSI) / Door and Access Systems Manufacturers Association, International (DASMA):

1. DASMA Thermal Performance Verification Program.
2. ANSI/DASMA 105 - Test Method For Thermal Transmittance And Air Infiltration Of Garage Doors.
3. ANSI/DASMA 163 - R-Value and U-Factor As Applied To A Residential or Commercial Garage Door.

B. ASTM International (ASTM):

1. ASTM A653/A653M - Standard Specification for Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
2. ASTM E283 - Standard Test Method for Determining Rate of Air Leakage Through Exterior Windows, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen.
3. ASTM E330 – Standard Test Method for Structural Performance of Exterior Windows, Doors, Skylights and Curtain Walls by Uniform Static Air Pressure Difference.

C. Consult factory for projects requiring Buy American requirements for American Recovery and Reinvestment Act, Build America Buy America Act or American Iron and Steel Certification.

#### 1.4 SYSTEM DESCRIPTION

A. Cycles:

**\*\* NOTE TO SPECIFIER \*\* Delete cycle life options not required. 10,000 cycles is standard.**

1. Cycle Life: 10,000 cycles.
2. Cycle Life: 25,000 cycles.
3. Cycle Life: 50,000 cycles.
4. Cycle Life: 100,000 cycles.
5. Cycle Life: \_\_\_\_ cycles.

B. Door Opening and Closing:

**\*\* NOTE TO SPECIFIER \*\* Delete operation options not required.**

1. Operation: Electric.
2. Operation: Manual.
3. Operation: Chain hoist.

C. Track and Operating Hardware:

**\*\* NOTE TO SPECIFIER \*\* Delete the track type options not required.**

1. Standard lift type.
2. Vertical lift type.
3. High lift type.
4. Follow Roof/Incline pitch type.
5. Low headroom type.

#### 1.5 SUBMITTALS

A. Submit under provisions of Section 01 30 00 - Administrative Requirements.

B. Shop Drawings: Indicate opening dimensions and required tolerances, jamb connection details, anchorage spacing, hardware locations, installation details, and special conditions.

C. Product Data: Provide information on components, application, hardware, and accessories.

**\*\* NOTE TO SPECIFIER \*\* Retain one or both paragraphs below. Retaining both paragraphs**

indicates "Two Stage Samples" process. Delete "Samples for Initial Selection" if colors have already been determined. Delete items not required.

- D. Samples for Initial Selection: Provide manufacturer's finish charts showing full range of colors and textures available for units with factory applied finishes.
- E. Samples for Verification: Provide for each type of exposed finish on the following components in manufacturer's standard sizes:
  1. Color Chip Sample.
  2. Glass Chip Sample.

**\*\* NOTE TO SPECIFIER \*\*** Include the following for projects requiring LEED certification. Credits are available for the use of recycled materials and also for regional materials if the project is located within a 500-mile radius of the C.H.I. manufacturing facility in Arthur, IL.

- F. Sustainable Design Submittals:
  1. Recycled products: Indicate percentage of recycled material used in the manufacturing of products and percentage classified as post-consumer.
  2. Regional products: Indicate location of product manufacturer and distance from manufacturing facility to project site.
- G. Closeout Submittals: Operation and maintenance data.

#### 1.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Manufacturer shall provide an overhead door system capable of withstanding positive and negative wind loads as required by local building code for 10,000 cycles.
- B. Installer Qualifications: Installer shall be authorized and qualified to install overhead door systems on the type and scope of project specified.
- C. Source Limitations: Provide overhead sectional doors from one manufacturer for each type of door. Provide operators and other accessories from source acceptable to overhead door manufacturer.

#### 1.7 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Store and dispose of all materials in accordance with federal, state, and local laws.

#### 1.8 PROJECT CONDITIONS

- A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's recommended limits.

#### 1.9 WARRANTY

- A. Manufacturer's limited warranty against manufacturing defect and product workmanship.
  1. Steel Door Sections: Used in commercial applications, under normal conditions, against splitting, cracking, rusting through or delaminating.
    - a. Warranty Period: 10 years from date of manufacture.
  2. Hardware, Including Springs: For defects in material or workmanship.
    - a. Warranty Period: 1 year from date of manufacture.

### PART 2 PRODUCTS

## 2.1 MANUFACTURERS

A. Acceptable Manufacturer: C.H.I. Overhead Doors, which is located at: 1485 Sunrise Dr.; Arthur, IL 61911; Toll Free Tel: 800-677-2650; Fax: 800-738-5006; Email: [aia@chiohd.com](mailto:aia@chiohd.com); Web: <http://www.chiohd.com>.

**\*\* NOTE TO SPECIFIER \*\*** Delete one of the following two paragraphs; coordinate with requirements of Division 1 section on product options and substitutions.

B. Substitutions: Not permitted.

C. Requests for substitutions will be considered in accordance with the provisions of Section 01 60 00 - Product Requirements.

## 2.2 COMMERCIAL INSULATED STEEL SANDWICH DOORS

A. Polyurethane Thermally Broken Insulated Steel Sandwich Doors: 1-1/2 inch thick.

1. Model 3207. Thermally broken insulated steel sandwich door.

- a. Appearance: Flush, woodgrain embossed.
- a. Exterior: 27-gauge, 0.015 inch (0.38 mm) polyester painted galvanized steel.
- b. Interior: 27-gauge, 0.015 inch (0.38 mm) polyester painted galvanized steel.
- c. Maximum Standard Door Size (WxH): 24 ft 2 inches (7.37 m) x 16 ft 0 inches (4.88 m). Consult factory for larger sizes.
- d. Thickness: 1-1/2 inches (38 mm).
- e. Joints: Tongue and Groove.
- f. Finish: White.
- g. Flush Sections: 21 inches (533 mm) and 24 inches (610 mm) based on overall door height.
- h. U-factor: 0.19 per ANSI/DASMA 105.
- i. Calculated R-Value: 11.63.
- j. Insulation: Thermally broken, foamed in place with CFC, HFC, HCFC and PFA free and non-VOC polyurethane insulation. Foam to have zero Ozone Depletion Potential (ODP) and zero Global Warming Potential (GWP).
- k. Air Infiltration: 0.15 per ANSI/DASMA 105, ASTM E283.
- l. DASMA Thermal Performance Verified Product
- m. IECC®, ASHRAE 90.1®, and California Title 24® compliant for thermal performance and air infiltration.
- n. Backer Plate: 24-gauge, 0.022 inch (0.56 mm) galvanized steel.
- o. End Stile: 24-gauge, 0.022 inch (0.56 mm) galvanized steel, painted white. Double end stile and hinges for 16 ft 3 inches (4.95 m) and wider

**\*\* NOTE TO SPECIFIER \*\*** Delete window lites options not required.

- p. Window Lites: 24 x 6 inches (610 x 152 mm). 1/2 inch (13 mm) plain DSB, insulated, matching frame.
- q. Window Lites: 24 x 6 inches (610 x 152 mm). 1/2 inch (13 mm) tinted, insulated, matching frame.
- r. Window Lites: 24 x 6 inches (610 x 152 mm). 1/2 inch (13 mm) tempered, insulated, matching frame.
- s. Window Lites: 24 x 12 inches (610 x 305 mm). 1/2 inch (19 mm) plain DSB, insulated, matching frame.
- t. Window Lites: 24 x 12 inches (610 x 305 mm). 1/2 inch (19 mm) tinted, insulated, matching frame.
- u. Window Lites: 24 x 12 inches (610 x 305 mm). 1/2 inch (19 mm) tempered, insulated, matching frame.
- v. Window Lites: 3 inches (76 mm) Exhaust Port.

w. Window Lites: 4 inches (102 mm) Exhaust Port.

**\*\* NOTE TO SPECIFIER \*\* Delete Window Lite Pattern options not required, or delete all.**

- x. Window Lite Pattern: Full width of section. Section(s) \_\_\_\_ from ground.
- y. Window Lite Pattern: Left side looking out, \_\_\_\_ wide by \_\_\_\_ high. Section \_\_\_\_ from ground.
- z. Window Lite Pattern: Right side looking out, \_\_\_\_ wide by \_\_\_\_ high. Section \_\_\_\_ from ground.
- aa. Window Lite Pattern: Per attached drawing.

**\*\* NOTE TO SPECIFIER \*\* Delete locking options not required.**

- bb. Locking: No Lock.
- cc. Locking: One Inside slide lock.
- dd. Locking: Two Inside slide locks.
- ee. Locking: Outside center lock.
- ff. Locking: Double lock bar.

**\*\* NOTE TO SPECIFIER \*\* Delete weather seal option not required.**

- gg. Weather Seal: U-shaped bottom astragal with aluminum retainer (standard).
- hh. Weather Seal: Top Seal
- ii. Weather Seal: Header and Jambs. Flexible one-piece vinyl extrusion.

**\*\* NOTE TO SPECIFIER \*\* Delete operation options not required.**

- jj. Operation: Manual.
- kk. Operation: Chain hoist. Not available for standard lift or low headroom track options.
- ll. Operation: Electric.

**\*\* NOTE TO SPECIFIER \*\* Delete jamb material option not required.**

- mm. Jamb Material: Wood.
- nn. Jamb Material: Steel – Sections will be 2 inches (51 mm) wider than opening.

**\*\* NOTE TO SPECIFIER \*\* Delete track type options not required.**

- oo. Track Type: Standard Lift, 15 inches (381 mm) radius standard. Consult factory for openings more than 300 square feet (27.9 square meters).
- pp. Track Type: Vertical Lift. Consult factory for doors over 16 ft (4.877 mm) or openings more than 300 square feet (27.9 square meters).
- qq. Track Type: High Lift. Consult factory for more than 120 inches (3.05 m) or openings more than 300 square feet (27.9 square meters). Specify Lift Amount: \_\_\_\_ inches (\_\_\_\_ mm).
- rr. Track Type: Follow Roof Line / Incline. Available in pitch increments of 0.5 from 0.5/12 to 12/12. Consult factory if less than 15 inches (381 mm) of headroom, openings more than 300 square feet (27.9 square meters) or pitch greater than 6/12.
- ss. Track Type: Low Head Room.

**\*\* NOTE TO SPECIFIER \*\* Delete front mount options not required.**

- 1) Front Mount: 12 inches (305 mm) Radius, 2 inches Track Only.
- 2) Front Mount: 15 inches (381 mm) Radius.
- 3) Rear Mount: 12 inches (305 mm) Radius, 2 inches Track Only.
- 4) Rear Mount: 15 inches (381 mm) Radius.

**\*\* NOTE TO SPECIFIER \*\* Delete track appearance options not required. Galvanized is standard.**

- tt. Track Appearance: Galvanized.
- uu. Track Appearance – White Powder Coat.
- vv. Track Appearance – RAL Powder Coat No.\_\_\_\_\_.
- ww. Track Size: Track mounting and size is based on door size and

weight. Lower track is adjustable for weathertight fit. Optional to upgrade to clip angle or continuous when not standard. Track will be minimum 16-gauge, 0.055 inch (1.39mm) galvanized steel. Gauge will increase based on design requirements. 2-inch (51 mm) track for 2 inch (51 mm) rollers or 3 inch (76 mm) track with 3 inch (76 mm) rollers.

- xx. Roller Assemblies: Galvanized steel adjustable roller holders with floating hardened steel bearing rollers, located at top and bottom of each side of each section. Size and type to be determined by the manufacturer based on door size and weight.
- yy. Hinges: 14-gauge, 0.070 inch (1.77 mm) galvanized steel standard to 24 ft 2 inches (7.37m). 11-gauge, 0.114 inch (2.89 mm) galvanized steel standard if larger.
- zz. Spring Counterbalance: Helically-wound, oil-tempered torsion springs mounted on cross-header shaft supported by galvanized steel ball bearing end plates and center carrier brackets as required. Springs to be individually calibrated to each door. Spring shafts are hollow or solid based on door size and weight. Counterbalance transferred to doors via aircraft quality braided steel lift cables.
- aaa. Spring Cycle Life: 10,000 cycles standard. Consult factory for extended life cycles up to 100,000 cycles. There are limitations based on door size and weight.

## 2.3 COMPONENTS

**\*\* NOTE TO SPECIFIER \*\*** Delete the following paragraph if doors are manually operated.

### A. Electric Operator:

- 1. Externally mounted on drive side of door.

**\*\* NOTE TO SPECIFIER \*\*** Delete power supply options not required.

- 2. Power Supply: 115 Volts AC single phase.
- 3. Power Supply: 208/230 Volts AC single or three phase.
- 4. Power Supply: 460 Volts AC three phase.
- 5. Manually operable in case of power failure.

**\*\* NOTE TO SPECIFIER \*\*** Delete control station power option and control station options not required.

- 6. Control Station Power: 24 VDC.
- 7. Control Station Power: 115 VAC.
- 8. Control Station: Keyed Switch.
- 9. Control Station: Two button (Open / Close) station.
- 10. Control Station: Three button (Open / Stop / Close) station.

**\*\* NOTE TO SPECIFIER \*\*** Delete paragraph if no safety device is specified for electrically controlled units or delete safety device options not required.

### B. Safety Reversing Device:

- 1. Safety Device: Photoelectric sensor; detect obstruction and reverse door without requiring door to contact obstruction.
- 2. Safety Device: Electric pneumatic edge; detect obstruction and reverse door upon contact with pneumatic hose.
- 3. Safety Device: Electric edge; detect obstruction and reverse door upon contact with electric strips in vinyl housing.
- 4. Safety Device: Electric edge; fail-safe, self-monitoring.

## PART 3 EXECUTION

### 3.1 EXAMINATION

- A. Do not begin installation until work areas have been properly prepared.

- B. If preparation is the responsibility of another installer, notify Architect of unsatisfactory conditions before proceeding.

### 3.2 INSTALLATION

- A. Install door assembly in accordance with manufacturer's instructions.
- B. Anchor to adjacent construction without distortion or stress.
- C. Securely brace door tracks suspended from structure. Secure tracks to structural members only.
- D. Fit and align door assembly including hardware, level and plumb, to provide smooth operation.

**\*\* NOTE TO SPECIFIER \*\*** Include the following paragraph if head and jamb weatherstripping is specified.

- E. Position head and jamb weatherstripping to contact door sections when closed; secure in position.

**\*\* NOTE TO SPECIFIER \*\*** Include the following paragraph if electrically operated doors are specified.

- F. Make wiring connections between power supply and operator and between operator and controls.

### 3.3 ADJUSTING

- A. Adjust to operate smoothly throughout full operating range.

### 3.4 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before substantial completion.

END OF SECTION